F A L L R I V E R L A K E - R E S E R V O I R A C C O U N T I N G

Calendar Year 2023

Date	2010 Survey Results 948.50 20,690		INFLOW	OUTFLOW	PRECIP	EVAP	Inactive Pool (Elev. 896')					Water Quality/Supply				
	EOM Elevation (MSL) 946.95	EOM Storage (AF) 17,569	Monthly Inflow (AF)	Monthly Outflow (AF)	Monthly Precip. (inches)	Reservoir Evap. (AF)	Inflow Share (AF)	Use (AF)	Evap. Share (AF)	EOM Storage (%)	EOM Storage (AF) 6,787	Inflow Share (AF)	Use (AF)	Evap. Share (AF)	EOM Storage (%)	EOM Storage (AF) 10,782
Jan	946.88	17,440	359	315	0.97	173	0	0	0	100%	6,787	107	129	106	77%	10,653
Feb	947.11	17,878	932	220	1.75	264	0	0	0	100%	6,787	520	0	161	80%	11,091
Mar	947.63	18,897	1,634	184	1.01	418	0	0	0	100%	6,787	974	0	259	87%	12,110
Apr	947.32	18,290	426	179	1.12	854	0	0	0	100%	6,787	223	282	547	83%	11,503
May	948.43	20,540	3,138	184	1.65	754	0	0	0	100%	6,787	1985	0	475	99%	13,753
Jun	948.18	20,007	692	188	1.58	991	0	0	0	100%	6,787	256	312	477	95%	13,220
Jul	947.48	18,603	272	615	1.69	1,061	0	0	0	100%	6,787	140	843	701	85%	11,816
Aug	946.87	17,421	278	403	3.84	1,045	0	0	0	100%	6,787	140	552	663	77%	10,741
Sep																
Oct																
Nov																
Dec																
TOTAL			7,732	2,289	13.61	5561	0	0	0			4344	2118	3390		

AF - Acre Feet
EOM - End of Month
Evap. - Evaporation
Precip. - Precipitation
MSL - Mean Sea Level

Inactive Pool -Storage below elevation 940 feet. Excempt from accounting unless below elevation 940 feet. Potential emergency use.
Water Quality/Supply - Storage between elevation 940 feet and 948.5 feet and is used to serve downstream water supply demands and water quality needs.